



# CERTIFICATE FOR CHINA COMPULSORY PRODUCT CERTIFICATION

本翻译文件不具有法律效力，  
不得单独使用  
This translated document  
does not have legal validity and  
cannot be used in isolation

**CERTIFICATE NO.:** 2024010307666029

**NAME AND ADDRESS OF THE APPLICANT**

DAERYUK CO., LTD.  
22-9, Pogong-ro234beon-gil, Pogok-eup, Cheoin-gu, Yong-in-si, Gyeonggi-do, Korea

**NAME AND ADDRESS OF THE MANUFACTURER**

DAERYUK CO., LTD.  
22-9, Pogong-ro234beon-gil, Pogok-eup, Cheoin-gu, Yong-in-si, Gyeonggi-do, Korea

**NAME AND LOCATION OF THE FACTORY**

DAERYUK CO., LTD.  
22-9, Pogong-ro234beon-gil, Pogok-eup, Cheoin-gu, Yong-in-si, Gyeonggi-do, Korea

**PRODUCT NAME,MODEL AND SPECIFICATION**

Moulded Case Circuit-breaker  
DBE 102BE,DBE 103BE; Ui:600V;Ue:AC220V/AC460V;  
In:51A,52A,53A,54A,55A,56A,57A,58A,59A,60A,61A,62A,63A,64A,  
65A,66A,67A,68A,69A,70A,71A,72A,73A,74A,75A,76A,77A,78A,79A,  
80A,81A,82A,83A,84A,85A,86A,87A,88A,89A,90A,91A,92A,93A,94A, 95A,96A,97A,98A,99A,100A;Over-current Trip  
Unit:Hydraulic Pressure Electromagnetic;AC220V:Ics:2.5kA;Icu:5kA;AC460V:Ics:1.25kA;Icu:2.5kA;Selectivity  
category:A;2P,3P

**STANDARDS AND TECHNICAL REQUIREMENTS FOR THE PRODUCTS**

GB/T 14048.2-2020

This is to certify that the above mentioned product(s) complies with the requirements of  
implementation rules for compulsory certification(REFNO. CNCA-C03-02:2024).

**Valid from:** Jul.29,2024

**Valid until:** Jul.28,2029

The certificate information and validity could be checked by scanning the QR code below or logging in to  
the website of the issuing authority, or on the website of the CNCA (www.cnca.gov.cn).



**SIGNATURE:**

谢肇煦



中国质量认证中心  
CHINA QUALITY CERTIFICATION CENTRE

CHINA QUALITY CERTIFICATION CENTRE CO., LTD.

