

Zertifikat

Certificate



Zertifikat Nr. Certificate No.
R 50063292

Blatt Page
0001

Ihr Zeichen Client Reference
Mr. Y.J. Hwang

Unser Zeichen Our Reference
ZKR3-KIS- 13004349 001

Ausstellungsdatum
31.05.2005

Date of Issue
(day/mo/yr)

Genehmigungsinhaber License Holder

Daeryuk Co., Ltd.
530, Samgye-ri, Pogok-myeon
Yongin, Gyeonggi-do 449-814
Rep. of Korea

Fertigungsstätte Manufacturing Plant

Daeryuk Co., Ltd.
530, Samgye-ri, Pogok-myeon
Yongin, Gyeonggi-do 449-814
Rep. of Korea

Prüfzeichen Test Mark

Geprüft nach Tested acc. to
EN 60934:2001



Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Geräteschutzschalter Circuit Breaker for Equipment

Type Designation	: DCP-5aDRbbcd	4
a stands for	: Number of Poles (1, 2, 3)	1
bb stands for	: Rated Current (In) in A (1 to 30)	1
c stands for	: Nature of Supply (A = a.c.)	1
d stands for	: Tripping Characteristics (I = instantaneous, H = high speed M = medium speed, L = low speed)	1
e stands for	: Auxiliary Circuit (S = none, W = auxiliary switch, E = AL switch)	1

Continued on page 0002

9

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.
This certificate is based on our Testing and Certification Regulation. The product
fulfills above-mentioned requirements, the production is subject to surveillance.

TÜV Rheinland Product Safety GmbH, Am Grauen Stein, D-51105 Köln

Tel.:(+49/221)8 06 - 13 71 Fax:(+49/221)8 06 - 39 35 e-mail: Althoff@de.tuv.com

Zertifizierungsstelle



Dipl.-Ing. U. Sonntag

Zertifikat

Certificate



Zertifikat Nr. *Certificate No.*
R 50063292

Blatt *Page*
0002

Ihr Zeichen *Client Reference*
Mr. Y.J. Hwang

Unser Zeichen *Our Reference*
ZKR3-KIS- 13004349 001

Ausstellungsdatum
31.05.2005

Date of Issue
(day/mo/yr)

Genehmigungsinhaber *License Holder*

Daeryuk Co., Ltd.
530, Samgye-ri, Pogok-myeon
Yongin, Gyeonggi-do 449-814
Rep. of Korea

Fertigungsstätte *Manufacturing Plant*

Daeryuk Co., Ltd.
530, Samgye-ri, Pogok-myeon
Yongin, Gyeonggi-do 449-814
Rep. of Korea

Prüfzeichen *Test Mark*

Geprüft nach *Tested acc. to*
EN 60934:2001



Zertifiziertes Produkt (Geräteidentifikation)
Certified Product (Product Identification)

Lizenzentgelte - Einheit
License Fee - Unit

Geräteschutzschalter Circuit Breaker for Equipment

Continued from page 0001

Rated Operational Voltage: 250V

Rated Frequency : 50/60Hz

Rated Switching Capacity : 6 x In

Rated Short-circuit
Capacity (Icn) : 1.5kA

Rated Conditional
Short-circuit Capacity : 1.5kA (PC1)

Mode of Tripping : HM (Hydraulic Magnetic)

Method of Operation : S-type

ANLAGE (Appendix): 1

Dem Zertifikat liegt unsere Prüf- und Zertifizierungsordnung zugrunde.
Das Produkt entspricht den o.g. Anforderungen, die Herstellung wird überwacht.
This certificate is based on our Testing and Certification Regulation. The product
fulfills above-mentioned requirements, the production is subject to surveillance.

TÜV Rheinland Product Safety GmbH, Am Grauen Stein, D-51105 Köln

Tel.:(+49/221)8 06 - 13 71 Fax:(+49/221)8 06 - 39 35 e-mail: Althoff@de.tuv.com

Zertifizierungsstelle

U. Sonntag
Dipl.-Ing. U. Sonntag

